




## Connections for Alarm inputs and outputs



To Phone Jack  
 Red  
 Green

This contact closes via a command from remote telephone


Transformer # PTD2420 (see accessories)



This contact closes upon an alarm condition such as Hi or Lo temperature

When this input is closed (shorted) an alarm is initiated and dial-out will commence

System Fault input

 Doylestown, PA 18901 USA Phone: 215-766 1487 - Fax: 215-766 1493 Email: info@scillc.com Web: www.scillc.com	Title: <b>CEO-24-HC22<sup>®</sup></b>			Print name: CEO-24	Drawn :
				Checksum: 6675	Checked :
				Software name:	Approved :Ricardo
	Date: <b>09 Jan 2007</b>	No.	Revision	Date	File name : CEO-24-HC22